



eurofins

Attestation

On 23 April 2012, Eurofins Product Testing A/S received a sample of an adhesive named

CT1 C-Tec N.I. Limited

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by 09.11.2010. (See report No. G15382B_01)

Evaluation of the test result according to EC 1:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 1000 µg/m³.
 - The sum of VOC ("TVOC") after 28 days meets the limit of 100 µg/m³.
 - The sum of SVOC after 28 day was below the limit of 50 µg/m³.
 - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
-

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products, if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

20 November 2013

Dr. Arja Valtanen
Analytical Service Manager

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75