

C-Tec N.I Limited
 Unit 6, Ashtree Enterprise Park
 BT34 1BY, Newry
 NORTHERN IRELAND

Eurofins Product Testing Denmark A/S
 Smedeskovvej 38
 8464 Galten
 Denmark

DK-CustomerSupport@cpt.eurofinseu.com
 www.eurofins.com

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD

12 February 2025

1 Sample Information

Sample name	CT1 Colours
Batch no.	4541045
Stated production date	11/11/2024
Product type	Joint sealant
Sample reception	06/12/2024


2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia	Pass	DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022
ABG/AgBB §	Pass	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (September 2024)
Belgian Regulation	Pass	Royal decree of May 2014 (C-2014/24239)
EMICODE	EC 1 PLUS	November 2024
Indoor Air Comfort §	Pass	Indoor Air Comfort 9.0 of June 2023
Indoor Air Comfort GOLD §	Pass	Indoor Air Comfort GOLD 9.0 of June 2023
Blue Angel (DE-UZ 123)	Pass	DE-UZ 123 for "Low-Emission Sealants for Interior Use", January 2019
BREEAM International	Exemplary Level	BREEAM International New Construction v6.0 (2021)
BREEAM NOR	Exemplary Level	BREEAM NOR v6.1 New Construction (2023)
EU Taxonomy	Pass	Regulation (EU) 2020/852 of the European Parliament and of the Council

Full details based on the testing and direct comparison with limit values are available in the following pages

Regarding pass/fail decision rule please see appendix

§ See section 4.4 on deviations



Mads Folkjær
 Analytical Chemist



Laura Hartung Sørensen
 Analytical Service Manager